

**Local Law No. 2 of 2018**

**A Local Law to amend Law #1 of 1989 (as revised and amended thereafter) by amending Article 18.50(3)[i]: COMMERCIAL SOLAR ENERGY SYSTEM as it pertains to security fencing**

**Section 1:**

ARTICLE 18: SOLAR ENERGY SYSTEMS, Section 18.50: COMMERCIAL SOLAR ENERGY SYSTEM of Local Law #1 of 1989 (as revised and amended thereafter, is hereby amended to replace the language in Section 3(i) with the following language:

- (i) The site plan shall include fencing of not less than 2.1 m (7 feet) in height or a combination of 1.8 m (6 ft) or more of fence fabric and a 300 mm (1 ft) or more extension utilizing strands of barbed wire or equivalent, as currently set forth in the National Electric Code. In the event that fencing as specified in the National Electric Code is changed, this provision shall default to those specifications set forth in the National Electric Code.

**Section 2: SEVERABILITY OF PROVISIONS**

Should any section or provision of this Local Law be declared null, void, voidable or invalid, such finding shall not affect the validity of the remaining portions of this local law.

**Section 3: EFFECTIVE DATE**

This Local Law shall take effect immediately upon filing with the New York State Secretary of State's Office.